

PHYSICAL TESTING REPORT



Metamark UK Ltd
Metamark House
Octimum Business Park
Forsyth Road
Woking
Surrey
GU21 5JF

FAO: Mr. Max Somper

Report of Tests on: MetaGuard FloorArt

Your Reference: Metamark MG-F

Lucideon Reference: UK201936-15027

Date Reported: 26-May-2020

Order Number: MS300420

Date Logged: 05-May-2020

Date(s) of Test(s): 20-May-2020 to 20-May-2020

Inclined Platform Test for Slip Resistance In Shod Conditions

DIN 51130:2014

No.	Operator 1 - Angle of Inclination	Operator 2 - Angle of Inclination
	°	°
1	6.2	7.6
2	6.3	8.2
3	5.9	8.4

Description of Test Specimen(s): 1 metaguard sheet

Average of Six Shod Results (Corrected): 7.9 °

Category: R9

The critical angle at which a test person reaches the limit of safe walking on an inclined plane is used as a measure of slip resistance.

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

End of Test Report

Mr Simon Hall
Manager